



บริษัท แสงเจริญ ฮอทดิพ กัลวาไนซ์ จำกัด

SANG CHAROEN HOT DIP GALVANIZE CO.,LTD.

丘建新電鍍工廠有限公司

1/1 หมู่ 4 ตำบล คูขวาง อำเภอ ลาดหลุมแก้ว จังหวัด ปทุมธานี โทร/โทรสาร:+66-2-599-4115-9
1/1 Moo.4 Thumbol Kukuang Amphur Ladlumkaew Pathumthani 12140 Tel/Fax:+66-2-599-4115-9

Record of Thickness Coating

Table with 3 rows: OWNER (Narawat Engineering Co.,Ltd.), CLIENT (New Energy Plus), PROJECT (Walkway XS53), Date Issued (22/7/2024), Inspection Sheet No (SCG/II. 24/010), Reference (2287/114324)

Standard Reference: ASTM A123 /A123 M - 17 (Standard Specification for Zinc (Hot Dip Galvanized) Coatings on Iron and Steel Products)

Sample Size: 3 Testing Method: Magnetic Thickness Measurements
Lot Size: 427 Serial Number :

Main data table with columns: No., Description of Articles, Steel Th(mm), Thickness Of Coating (µm) (5 columns), Average, Remark. Contains 3 rows of data for different samples.

Minimum Average Coating Thickness Grade by Material Category

Table showing Minimum Average Coating Thickness Grade by Material Category. Columns include Material Category, Steel Thickness Range (Measured), in. (mm), and thickness requirements for various categories like Structural Shapes, Strip and Bar, etc.

Remark: 1µm = 7.067 gram per square meter

Inspected By:

(Signature of Mr. Tanawat Sukned)

(Mr.Tanawat Sukned)
Q.C. Engineer



Approved By:

(Signature of Mr. Sakchai Saeku)

(Mr.Sakchai Saeku)
Factory Manager